



Product Service

CERTIFICATE

No. Z1 11 08 77543 001

Holder of Certificate: **RP-Technik e.K.**
Hermann-Staudinger-Str. 10-12
63110 Rodgau
GERMANY

Production Facility(ies): 77542

Certification Mark:



Product: **Power supply equipment**

Model(s): **MidiControl
MultiControl**

Parameters:		MidiControl	MultiControl
	Rated voltage:	400/230 V, 3NPE	400/230 V, 3NPE
	Rated frequency:	50 Hz	50 Hz
	Rated current:	3 A or 6 A (charging)	3 A or 6 A (charging)
	Max. output:	Max 5.3 kW (depending on batteries)	Max 100 kW (depending on batteries)

Tested according to: EN 50171:2001

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 028-71382833-000

Date, 2011-08-18

(Theo Butz)

Page 1 of 1

